

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LI12828**

Official Laboratory Report

Report To: RICK MAHONEY
6251 S BIRD LK RD
OSSEO MI 49266

System Name/Owner:	PITTSFORD AREA SCHOOL	WSSN/Pool ID:	2002930
Collection Address:	9304 HAMILTON STREET, PITTSFORD	Source:	TYPE II
Collected By:	RICK MAHONEY	Site Code:	
Township/Well#/Section:	PITTSFORD//	Collector:	Other
County:	Hillsdale	Date Collected:	10/23/2018 16:45
Sample Point:	TREATED SAMPLE TAP	Date Received:	10/25/2018 08:37
Water System:	Treated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Arsenic	Not detected	10/26/2018	0.002	0.010	EPA 200.8	7440-38-2

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**Branch-Hillsdale-St. Joseph Health Dept
20 Care Drive
Hillsdale, MI 49242
517 437-7395**

CAS# : Chemical Abstract Service Registry Number	mg/L : milligrams / Liter (ppm)	Laboratory Contact: Scott Hayward
MCL : Maximum Contaminant Level	ppm : parts per million	
AL : Action Level	MPN : Most Probable Number	
RL : Reporting Limit	CFU : Colony Forming Unit	



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



C. HEIDI GREYER
DIRECTOR

November 20, 2018

VIA E-MAIL

PITTSFORD HIGH SCHOOL
9304 E. HAMILTON ST.
PITTSFORD, MICHIGAN 49271

WSSN: 2002930

Dear School Administrator and Drinking Water Operator:

SUBJECT: PITTSFORD HIGH SCHOOL
Per- and Polyfluoroalkyl Substances (PFAS)

As you may be aware, the Michigan PFAS Action Response Team (MPART) has undertaken a proactive effort to investigate sources and locations of PFAS contamination in Michigan, to protect our drinking water, and to inform the public about PFAS. This involves the work of ten state departments, in coordination with local and federal officials.

One vital piece of this effort is the ongoing collaboration between the Michigan Department of Environmental Quality (MDEQ) and our water supply partners. It is through your generous participation that we are able to set and achieve our goal: to proactively test all community water supplies and schools that are classified as non-transient non-community water supplies for PFAS contamination. Once complete, this study will be an invaluable tool in determining the extent of PFAS in Michigan's drinking water, and empowering the MPART in the pursuit of their mission. We thank you for your continuing partnership, collaboration, and dedication to the residents of our great state.

This letter is intended to provide the results of PFAS analyses in samples collected from the PITTSFORD HIGH SCHOOL, WSSN # 2002930 (water supply) on the date(s) indicated below.

The table below summarizes the sampling results. A copy of the laboratory report is enclosed for your review. The analyses of these samples reported less than 10 parts per trillion (ppt) for perfluorooctanesulfonic acid (PFOS) and perfluorooctanoic acid (PFOA). Your water supply may have returned results greater than non-detect (ND) for the total amount of PFAS analytes tested for. An ND result means the analyte was not detected. Neither the MDEQ nor the United States Environmental Protection Agency (USEPA) have any guidance values for these other analytes at this time. If additional guidance and/or comparison values are developed for these or other PFAS chemicals in the future, we may reevaluate this water supply.

Date Collected	Sampling Location	PFOS + PFOA (ppt)	LHA (ppt) PFOS + PFOA	Total Tested PFAS (ppt)
10/2/2018	Well 1	ND	70	ND
10/2/2018	Well 2*	ND	70	ND

ND – The parameter was not detected based on the laboratory's analytical report.
See Official lab results for test method used. *Surrogate recovery outside of control limits.

Currently, there is no regulatory drinking water standard for any of the PFAS chemicals. However, in May 2016 the USEPA established a non-regulatory Lifetime Health Advisory (LHA) for two of these chemicals, PFOS and PFOA. The LHA for PFOS and PFOA is 70 ppt combined, or individually if only one of them is present. The USEPA recommends that this LHA applies to both short-term (i.e., weeks to months) scenarios during pregnancy and lactation, as well as to lifetime-exposure scenarios. The LHA is the level, or amount, below which no harm is expected from these chemicals. The Michigan Department of Health and Human Services (MDHHS), as well as the MDEQ, have used this LHA of 70 ppt to inform decisions on actions that should be taken or are recommended to reduce exposure and prevent increased risk to public health from these PFAS contaminants. The USEPA has not set health advisory levels for the other PFAS compounds because not enough is known about them.

Additional information on the health effects of PFAS can be found on the Agency for Toxic Substances and Disease Registry (ATSDR) website listed at the end of this correspondence.

The concentrations of PFOS and PFOA in these samples are well below the USEPA LHA of 70 ppt and are not expected to result in adverse health effects as long as the concentrations are shown to remain below the LHA over time.

Because of the detection of low levels found in the water supply, we have the following recommendations for your consideration. These recommendations are essentially the same actions we have advised public water systems to follow for the past 30-plus years when a new contaminant has been confirmed as present in their drinking water.

1. Inform the public of these sample results through posting on your website or other means. The MDEQ, in collaboration with the MDHHS, has developed a toolkit containing communication templates to help notify school staff, students, and parents on the presence of PFAS in the drinking water and the response measures that are being initiated. This is a resource available to you if you choose and can be modified to fit your needs. The toolkit is available at www.michigan.gov/pfasresponse and click on "visit news and education."
2. Please continue with your regularly scheduled monitoring. The MDEQ recommends you also continue monitoring for PFAS on an annual basis to demonstrate the concentrations are consistently and reliably below any existing LHA.

These recommendations are based on the best available and most current information and may change depending on additional information related to site conditions; the availability of new data; or other new information as it becomes available. We may recommend further action at that time.

PITTSFORD HIGH SCHOOL

Page 3

November 20, 2018

As part of the MDEQ's proactive statewide sampling initiative, the results of this sampling will be posted online on the MPART website within 48 hours of this notification. The results can be found online by going to the MPART website address listed below, and by clicking on "Michigan PFAS Sites," and scrolling down and selecting "Public Water Supply Information." We recommend you inform your consumers as soon as possible. If you need assistance, please contact me.

For information on PFOS, PFOA, and other PFAS, including possible health outcomes, you may visit these websites:

- **State of Michigan PFAS Action Response Team (MPART)** website serving as the main resource for public information on PFAS contamination in Michigan:
www.michigan.gov/pfasresponse
- **United States Environmental Protection Agency (USEPA)** website including basic information, USEPA actions, and links to informational resources:
www.epa.gov/pfas
- **Agency for Toxic Substances and Disease Registry (ATSDR)** website including health information, exposure, and links to additional resources:
www.atsdr.cdc.gov/pfas

Thank you once again for your continued collaboration with this investigation. The ongoing partnership between the MDEQ and Michigan's public water supplies plays an integral role in the state's continued efforts to ascertain and address the incidence of PFAS in drinking water for Michiganders.

If you have any questions concerning this sampling, please contact me at the telephone number below; by email at DEQ-PFAS-DrinkingWater@michigan.gov; or by mail at DEQ-DWMAD, P.O. Box 30817, Lansing, Michigan 48909-8311.

Sincerely,

Lois Elliott Graham

Lois Elliott Graham, R.S., M.S.A.
Drinking Water and Municipal Assistance Division
810-730-8674

Enclosure

cc: Mr. Paul Andriacchi, Branch-Hillsdale-St Joseph Community Health Agency
Mr. Steven Crider, Supervisor, Drinking Water Unit, MDHHS
Mr. Dan Dettweiler, MDEQ